



SMALL TOWN, BIG BEACH™

Department of Fire and Emergency Services Parade Fire Safety Requirements Checklist

Event: _____; Date: _____

Float Name: _____

Responsible Party: _____

By Order of the Fire Marshal	
Applicable while riding in, on, or adjacent to any float or parade vehicle.	
Code Reference: IFC 2015 101.2; Updated January 2018	
P	F
	Use this checklist as a guide prior to parade. Fire prevention inspection follows similar format.
	Each float shall have a designated capable adult with the responsibility to ensure the overall safety and fire safety.
	All floats shall be equipped with a minimum of one 2A 10BC fire extinguisher per each rider division.
	Extinguishers shall be securely mounted, unobstructed.
	The riders knowledgeable in fire extinguisher locations and proper extinguisher operation.
	Extinguisher shall be currently certified by a licensed fire extinguisher contractor or current store receipt attached.
	Smoking is prohibited while riding in, on, or adjacent to any float or parade vehicle.
	A No Smoking Sign shall be securely attached and visible to all riders.
	Fireworks, pyrotechnics, flammable liquids or gases, open flame, or other hazards are prohibited.
	Electrical wiring and fuel lines in close proximity to persons shall be inspected by a qualified mechanic.

Point of Contact:

Department of Fire and Emergency Services
 1921 W. First St., Gulf Shores, AL 36542
 George F, Surry, Fire Marshal
 Office: (251) 968-7422; Direct: (251) 269-7996
 E-Mail: gsurry@gulfshoresal.gov
 Web: <http://www.gulfshoresal.gov/719/Fire-Marshal>